

**Millard Public Schools**

Rockwell Elementary – Skylight Replacement Ph. II  
Omaha, NE

**BID TIME/DATE: 10:30 a.m. on 12-13-18**

This addendum is issued by the Architect to all known bidders prior to the receipt of Proposals. Bidders shall acknowledge the receipt of this Addendum by so indicating on the Proposal Form. All information and instructions given herein shall become part of the Contract Documents.

**DRAWINGS**

Sheet A1.2 Photos and Details

Refer to detail 2A: Delete note “076200 New 24 ga. counterflashing,” and insert the following:  
“.063 aluminum slip flashing-by Skylight Mfr.” (This flashing at roof area #2 is being replaced so it matches the skylight finish).

Refer to detail 2B: Change note “076200 new .063 aluminum slip flashing” to read: “New .063 aluminum slip flashing by Skylight Mfr. @ roof area 3.” (NOTE: This flashing already exists at Roof area #1 and is to remain).

**END OF ADDENDUM NO. 1**

Attachments: Pre-Bid Meeting Attendance List

Meeting Sign-In: MPS Summer 2019 Projects - Rockwell Elem. - Skylight Repl. Ph. II  
 28 November 2018 10:30 a.m. BVH Project #18279

Name	Company/Representing	Telephone	E-mail
1. Kelley Rosburg	BVH Architecture	402-245-3060	krosburg@bvh.com
2. GARY MARTIN	SPEEPRO INC	402-290-5785	INFO@SPEEPROINC.COM
3. JOHN BRENNAN	MPS	402 715 1145	JTBRENNAN@MPSOMAHA.COM
4. Tommy Livermore	Bredco	402-250-5884	tommy@lebradco.com
5. Lisa Cummings	McKinnis	402-306-1943	lisa.cummings@mcKINNISINC.COM
6.			
7.			
8.			
9.			
10.			
11.			
12.			
13.			
14.			