

addendum

addendum no. 02

date: 2/8/2019

bid date: 2/12/2019

project name: MPS Cather Switchboard Replacement

project no: 18358

This addendum is hereby made a part of the contract documents to the same extent as if it were originally included therein. Contract documents shall be considered modified or revised as hereinafter described.

general

1. OPPD representative for MPS is David Ortiz.
2. Contractor shall not include fire watch in their bid, MPS will provide (or negotiate) if Fire Marshall requires fire watch.

specifications

1. Section 262416 Panelboards: Part 2.8, A, 2 – Delete this paragraph. 800A main breaker for panel MDP does not require ground fault protection.

drawings

1. Drawing e1 – Electrical Plans & Riser Diagram
 - a. Provide new housekeeping pad at new MDP location.
 - b. Coordinate MDP location with overhead gas service and relocate low voltage wiring as needed for installation.

end of addendum