

TCEP Project No.: 097-043-19  
LPS Bid No.: 9620

## **ADDENDUM NO. 1**

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 1-1 thru 1-2. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 1 on the Bid Proposal Form in the place provided.

### **GENERAL**

#### **Specification**

##### **Item 1-1: Section 01 10 00 – Summary**

Refer to Paragraph 1.2.A; Change paragraph to read as follows: The Work involves all construction indicated on the drawings and specifications, included but not limited to the following: Electrical work associated with light fixture replacements at Lincoln Southwest High School, Lincoln Southeast High School, Lincoln East High School, Lincoln High School, Lincoln Northeast High School and Lincoln North Star High School.

### **ELECTRICAL**

#### **Drawings**

##### **Item 1-2: Sheet 301.E101 – Lincoln High School Main Gym Second Floor Lighting Plan**

Add the following sentence to key note 1: Fixtures shall be mounted at same mounting height as existing fixtures in lieu of level with the bottom of structure.

END OF ADDENDUM NO. 1